

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

REQUEST FOR INFORMATION

No. 00015

Phone: 516-921-7100

Fax: 516-921-7920

TITLE: Chemclad Coating

DATE: 8/28/2009

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Allan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 9/4/2009

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

August 28, 2009
Chemclad Coating

I could not find the specifications for the Enecon Chemclad. There are two different types SC and XC. Is there also a type of termination detail (Rain infiltration between coating and basin).

CC: File

PROPOSED SOLUTION:

ANSWER:

August 28, 2009

The spec asks for SC. I don't see anything about termination. This is like a super paint that should finish in a straight line at the top of the basin (or possibly some point above the maximum water level where it would look OK).

Requested By: E.W. Howell Co., LLC

Date: _____

Signed: _____
Lauren Bergin